

TAMILNADU FIRE AND RESCUE SERVICE
SCHOOL NO OBJECTION CERTIFICATE.

R.C.NO: 72 / M.M.Nagar / 2024.


Date: 11.09.2024.

Certified that the M/s, SHREE NIKETAN PATASALA, CBSE SCHOOL AT S.NO: 248/2B1B, 248/2D, 248/88, 248/97, 248/2C, 248/87, 248/89, Dollars Colony, Vengambakkam, Agaramthen Village, Chitlapakkam Panchyat, Tambaram East, Chengalpet District . Comprised of 7928.00 Sq.mtr, Land area is 3994.00 Sq.mtr, Ground Floor area is 3706.00 Sq.mtr, First Floor area is 3871.00 Sq.mtr, Second Floor Occupied by SHREE NIKETAN PATASALA have complied with the fire prevention and fire safety requirements in accordance with rule of state Fire Service Rules and verified by the officers concerned of fire service on 10.09.2024 in the presence of Mr.P.KARTHIKEYAN, Station Officer in the presence of SHREE NIKETAN PATASALA at SHREE NIKETAN CBSE SCHOOL at S.NO.248/2B1B, 248/2D, 248/88, 248/97, 248/2C, 248/87, 248/89, Dollars Colony, Vengambakkam, Agaramthen Village, Chitlapakkam Panchyat, Tambaram East, Chengalpet District and that the building (Premises is fit for occupancy Class School Premises with the effect from 11.09.2024 to 10.09.2025 for a period of ONE YEAR in accordance with rule and subject to compliance of the conditions.

CONDITIONS:

1. This No Objection Certificate valid for one year only from the date of issue.
2. Fire Safety systems should be maintained in good working condition.
3. Mock Drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
 - a. Building occupancy capacity should be no more then 4 people per Square meter as per the National Building Code-2016.
 - b. The staircase treads and flooring shall be treated with rough finish (Grooving) to Avoid falling of Children.
 - c. As per para 6.3 of the BIS Standards IS:14435:1997 as the Class Rooms have only one entrance the capacity of the class room shall have to limited to 45 students .
 - d. Hose Reel Home system should be provided with in one year in all floors.

Office Seal



TO:

M/S, Shree Niketan Patasala CBSE School,
Dollars Colony, Vengambakkam,
Chitlapakkam panchayat, Tambaram East,
Chengalpattu District.

Copy to:

District officer, Chengalpattu District.

P. Karthikeyan

Station Officer,

Fire and Rescue Services Station,
Maraimalainagar, Chengalpattu District.